

TÜV Rheinland Energy GmbH  
51101 Köln

International Compressor Distribution n.v.  
Boomsesteenweg 957  
B-2610 Wilrijk  
Belgium

**931 / 21239011 / 01\_WISAIR**

Norbert Horlemann  
Tel. +49 221 806-1896  
Fax +49 221 806-1461  
Mail horlema@de.tuv.com  
16 March 2017

**Test certificate  
Validation according ISO 8573-1: 2010 Part 1:  
Contaminants and purity classes**

Dear Sir or Madam,

We have measured the total oil content (aerosols, liquids and vapours) in the outlet air stream of an WISAIR oil-free water injected screw air compressor. The measurements were done in accordance with the following guidelines and standards:

ISO 8573-1 : 2010 Part 1 : Contaminants and purity classes

ISO 8573-2 : 2007 Part 2: Test methods for aerosol oil content method B1 (full flow method)

ISO 8573-5 : 2001 Part 5: Test methods for oil vapour and organic solvent content

This being a type test, covering the entire range of oil free water injected screw air compressors

WIS 20V (15 kW / 20 hp) to WIS 75V (55 kW / 75 hp) and

WIS 40 (30 kW / 40 hp) to WIS 75 (55 kW / 75 hp)

a model was randomly selected for the tests.

For the tests a compressor type: WIS 75V with integrated dryer was selected. The tests were carried out at the outlet of the air compressor without any oil removal devices in between the compressor and the measurement point. The conditions of the test were:

Temperature at the measurement point (Membrane): ca. 28 °C

Temperature at the measurement point (Carbon): ca. 27° C

Pressure at the measurement point (Membrane): ca. 7.1bar (e)

Pressure at the measurement point (Carbon): 6.8 bar(e)

Maximum Free Air Delivery: ca. 150 l/s @ 13.0 bar (e)

TÜV Rheinland Energy GmbH  
Am Grauen Stein  
D-51105 Köln


Phone +49-221-806-5200  
Fax +49-221-806-1349  
Mail tre-service@de.tuv.com  
Web www.umwelt-tuv.de

District Court and  
Managing Director

Managing Director  
Dirk Fenske

District Court  
Cologne HRB 56171  
Ust.-Id-Nr.: DE 814653989

Principle diagram for full flow measurement of Aerosols and liquids as per ISO 8573 Part 2, method B1



Legend :

P : Pressure indicator

T : Temperature indicator


M : Measurement point with membrane

F : Flow meter

S : Silencer

C : Measurement point for oil vapour

Principle diagram for measurement of oil vapour and organic solvent content as per ISO 8573 Part 5



It is to certify that at the test conditions, no oil ( $c < 0.01 \text{ mg/m}^3$ ) deriving from the compressor (including all hydrocarbons C6 and above) could be determined in the compressed air stream. On the basis of this test, we can certify the results to be valid for the above mentioned of oil free water injected screw air compressors

WIS 20V (15 kW / 20 hp) to WIS 75V (55 kW / 75 hp) and  
 WIS 40 (30 kW / 40 hp) to WIS 75 (55 kW / 75 hp)

It is to certify that the quality of air from the above compressors qualifies to be in the category 'Class 0' in terms of total oil content, as defined in the standard ISO 8573-1 : 2010 Part 1

A detailed report with all conditions of the tests and results is available.

Best Regards

i. V.



Dr. rer. nat. Walter Dormagen

i. A.



Dr. rer. nat. Norbert Horlemann